बिड संख्या/Bid Number: GEM/2026/B/8099759

दिनांक /Dated: 15-10-2026

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	05-11-2026 10:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	06-11-2026 10:00:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	120 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Coal
विभाग का नाम/Department Name	Coal India Limited
संगठन का नाम/Organisation Name	South Eastern Coalfields Limited
कार्यालय का नाम/Office Name	Secl Bilaspur Chhattisgarh
शिकायत निवारण के संपर्क विवरण/ Contact details of Grievance redressal	HOD Email id :gmmm.secl.cil@coalindia.in Buyer Email id: somm.gvr.secl@coalindia.in
कुल मात्रा/Total Quantity	4300
वस्तु श्रेणी /Item Category	LED Luminaire For Floodlight Conforming To IS 10322 (Part 5/Section 5) (V3) , LED Luminaire For Road And Street Lights Conforming To IS 10322 (Part 5/Section 3) (V3) , LED Batten Light (LED Tube Light) (V2) , 150 watt street light , 190 watt Street light , 190-watt LED type High bay light
GeMARPTS में खोजी गई स्ट्रिंग्स / Searched Strings used in GeMARPTS	190-watt LED type High bay light
GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS	LED Luminaire for High Bay Lighting, LED Luminaire For Road And Street Lights Conforming To IS 10322 (Part 5/Section 3) (V3), LED Tube Light (Retrofit Type), Hand Held Search Light, 7 Watt White-LED Based Solar Street Lighting System As Per MNRE Specification, LED Luminaire For Floodlight Conforming To IS 10322 (Part 5/Section 5) (V3), 12 Watt White-LED Based Solar Street Lighting System As Per MNRE Specification, LED Luminaire (Recessed Luminaire) (Ceiling Light) Conforming To IS 10322 (Part 5/Section 2) (V4), High Mast Lighting Octagonal Tower With Solar Based LED Street Light (V2), LED Machine Work Lamp
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	• LED Luminaire for High Bay Lighting
वर्षों के अनुभव के लिए एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience	Yes | Complete
वर्षों के अनुभव के लिए स्टार्टअप को छूट प्राप्त है / Startup Relaxation for Years Of Experience	Yes | Complete

बिड विवरण/Bid Details	
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	190-watt LED type High bay light
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	7 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य / Estimated Bid Value	8472018.86
Payment Timelines	Payments shall be made to the Seller within **21** days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/Evaluation Method	Item wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाईजरी बैंक/Advisory Bank	State Bank of India

Schedule 1 ईएमडी राशि/EMD Amount (In INR)	18172
Schedule 2 ईएमडी राशि/EMD Amount (In INR)	10716
Schedule 3 ईएमडी राशि/EMD Amount (In INR)	16480
Schedule 4 ईएमडी राशि/EMD Amount (In INR)	10478
Schedule 5 ईएमडी राशि/EMD Amount (In INR)	1322
Schedule 6 ईएमडी राशि/EMD Amount (In INR)	12149
Schedule 7 ईएमडी राशि/EMD Amount (In INR)	86400
Schedule 8 ईएमडी राशि/EMD Amount (In INR)	13722

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%)/ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	4

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). The EMD Amount will be applicable for each schedule/group selected during Bid creation.

(c).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

(d).ईएमडी और संपादन जमानत राशि लाभार्थी के पक्ष में होनी चाहिए। / Earnest Money Deposit (EMD) shall also be accepted by the buyer in the form of a surety bond.

लाभार्थी /Beneficiary :

SECL GEVRA AREA
SOMM OFFICE OF THE GENERAL MANAGER SECL GEVRA AREA KORBA CHATTISGARH PO- GEVRA PROJECT PINCODE-495452 SECL Bilaspur Chhattisgarh, COAL INDIA LIMITED, South Eastern Coalfields Limited, Ministry of Coal (Secl Gevra Area)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता / MII Purchase Preference

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes

मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers availabele upto price within L1+X%	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं/सेवा प्रदाता को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% / Purchase Preference to MSE OEMs/ Service Provider available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माता/सेवा प्रदाता को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Percentage of Bid quantity/amount for MSE OEMs/ Service Provider Purchase preference	25

ट्रेड्स भुगतान संबंधी विवरण/TReDS Payment Details

This Bid provides for Trade Receivables Discounting System (TReDS) as Preferred mode of payment. For MSME sellers, payments may be processed through a TReDS exchange in which the Buyer is registered, subject to applicable policy and regulatory guidelines. Accordingly, sellers intending to avail payment through TReDS are required to be registered with at least one TReDS exchange in which the buyer is registered.

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
2. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Experience Criteria" as defined above subject to their meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
3. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage o

local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023. OM_No.1_4_2021_PPD_dated_18.05.2023 for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017 and its subsequent Orders/Notifications issued by concerned Ministry .Benefits of MSE will be allowed only if seller/service provider is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

4. **Purchase preference to Micro and Small Enterprises (MSEs):** Purchase preference will be given to MSEs having valid Udyam Certificate and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service, and Buyer will decide eligibility for purchase preference based on documentary evidence submitted in case of product bids, whereas in case of services the eligibility is automatically validated. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM_No.1_4_2021_PPD_dated_18.05.2023 for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.
5. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

6. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

i. If number of technically qualified bidders are only 2 or 3.
ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

मूल्यांकन विधि(मदवार मूल्यांकन विधि) / Evaluation Method (Item Wise Evaluation Method)

Contract will be awarded schedule wise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

मूल्यांकन अनुसूचियां / **Evaluation Schedules**	अनुमानित मूल्य / **Estimated Value**	वस्तु/श्रेणी / **Item/Category**	मात्रा / **Quantity**
Schedule 1	908600	Led Luminaire For Floodlight Conforming To Is 10322 (part 5/section 5) (v3)	200
Schedule 2	535800.24	Led Luminaire For Floodlight Conforming To Is 10322 (part 5/section 5) (v3)	200

Schedule 3	823999.9	Led Luminaire For Road And Street Lights Conforming To Is 10322 (part 5/section 3) (v3)	500
Schedule 4	523948.32	Led Luminaire For Road And Street Lights Conforming To Is 10322 (part 5/section 3) (v3)	700
Schedule 5	66080	Led Batten Light (led Tube Light) (v2)	700
Schedule 6	607499.4	150 Watt Street Light	500
Schedule 7	4319989.44	190 Watt Street Light	1200
Schedule 8	686101.56	190-watt Led Type High Bay Light	300

LED Luminaire For Floodlight Conforming To IS 10322 (Part 5/Section 5) (V3) (200 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	**System Wattage (in Watt)**	500
	Minimum LED Luminaire System Efficacy (in lumen/watt)	100
	LED Colour Temperature [Hint: Warm White (2700K-3000K), Bright White (3500 K-4000 K), Cool White/Daylight (5000 K-6500 K)]	6500 K
Construction	Ingress Protection (Entire Housing)	IP66 Or higher
	Minimum Internal Surge Protection (in kV)	4, 5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aditya Paliwal	495452,SECL GEVRA AREA (GST- 22AADCS2066E9ZL)	200	60

LED Luminaire For Floodlight Conforming To IS 10322 (Part 5/Section 5) (V3) (200 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	**System Wattage (in Watt)**	400
	Minimum LED Luminaire System Efficacy (in lumen/watt)	100
	LED Colour Temperature [Hint: Warm White (2700K-3000K), Bright White (3500 K-4000 K), Cool White/Daylight (5000 K-6500 K)]	5700 K
Construction	Ingress Protection (Entire Housing)	IP66 Or higher
	Minimum Internal Surge Protection (in kV)	5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aditya Paliwal	495452,SECL GEVRA AREA (GST- 22AADCS2066E9ZL)	200	60

LED Luminaire For Road And Street Lights Conforming To IS 10322 (Part 5/Section 3) (V3) (500 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	**System Wattage (in Watt)**	150
	LED Luminaire System Efficacy (in lumen/watt)	100, 120, 140 Or higher
	LED Colour Temperature [Hint: Warm White (2700K-3000K), Bright White (3500 K-4000 K), Cool White/Daylight (5000 K-6500 K)]	6500 K
Construction	Ingress Protection (Entire Housing)	IP66 Or higher
	Minimum Internal Surge Protection (in kV)	4, 5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aditya Paliwal	495452,SECL GEVRA AREA (GST- 22AADCS2066E9ZL)	500	60

LED Luminaire For Road And Street Lights Conforming To IS 10322 (Part 5/Section 3) (V3) (700 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	**System Wattage (in Watt)**	100
	LED Luminaire System Efficacy (in lumen/watt)	120, 140 Or higher
	LED Colour Temperature [Hint: Warm White (2700K-3000K), Bright White (3500 K-4000 K), Cool White/Daylight (5000 K-6500 K)]	5000 K, 5700 K

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Construction	Ingress Protection (Entire Housing)	IP65, IP66 Or higher
	Minimum Internal Surge Protection (in kV)	4, 5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aditya Paliwal	495452,SECL GEVRA AREA (GST- 22AADCS2066E9ZL)	700	60

LED Batten Light (LED Tube Light) (V2) (700 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification]

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	**Rated Wattage (in Watts)**	20.0
	Length of LED Batten Light	4.0 **(foot)**
	Rated Luminous Efficacy (in lumen/watt)	110 Or higher
	LED Colour Temperature [Hint: Warm White (2700K-3000K), Bright White (3500 K-4000 K), Cool White/Daylight (5000 K-6500 K)]	6500 K

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aditya Paliwal	495452,SECL GEVRA AREA (GST- 22AADCS2066E9ZL)	700	60

150 Watt Street Light (500 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

क्रेता विशिष्टि दस्तावेज़ /Buyer Specification Document	Download

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aditya Paliwal	495452,SECL GEVRA AREA (GST- 22AADCS2066E9ZL)	500	60

190 Watt Street Light (1200 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

क्रेता विशिष्टि दस्तावेज़ /Buyer Specification Document	Download

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aditya Paliwal	495452,SECL GEVRA AREA (GST- 22AADCS2066E9ZL)	1200	60

190-watt LED Type High Bay Light (300 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

क्रेता विशिष्टि दस्तावेज़ /Buyer Specification Document	Download

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aditya Paliwal	495452,SECL GEVRA AREA (GST- 22AADCS2066E9ZL)	300	60

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. **Generic**

   OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be (Increased quantity ÷ Original quantity) × Original delivery period (in days), subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Generic**

   Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

3. **Scope of Supply**

   Scope of supply (Bid price to include all cost components) : Only supply of Goods

4. **Generic**

   Manufacturer Authorization: Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

5. **Warranty**

   Warranty period of the supplied products shall be 3 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods.

The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

6. **Generic**

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

a. Copy of PAN Card.

b. Copy of GSTIN.

c. Copy of Cancelled Cheque.

d. Copy of EFT Mandate duly certified by Bank.

7. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

8. **Forms of EMD and PBG**

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

SECL GEVRA AREA
payable at
GEVRA
.
Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

9. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of

SECL GEVRA AREA
payable at
GEVRA
. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.

10. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

1. **Technical Specification/Golden parameter of 500-watt, flood light**

Parameter	Technical requirement
1. LED description	500-watt flood light
2. Ingress protection (IP Rating)	as per IS 10322 (Part 5/section 5):2012 as applicable, latest, IP 66
3**.** Rated voltage:	230 V AC 50 Hz

4**.** Input operating voltage range, frequ ency and tripping	140-to-270-volt AC, 50 Hz with auto cut off below 120V and higher 300Volt
5**.** LED Luminaries as per the IS:16107(Part-2/sec-1)/2012 latest & Type of mod ule as per the IS:16103(Part-2)/2012	Type B & type 3
6. Color Temperature (in K)	(+/-500K) 6500k
7**.** LED Luminaries for road and street li ghting shall comply with	Compulsory Registration (CRS) of BIS for sa fety as per IS 10322 (Part 5/Section 3): 20 12 as applicable on date.
8. Length of ISI marked three core wire (shall be provided **along with supply o f material):**	50 cm minimum with each fitting.
9. Working life for LED	(Minimum 50,000 burning hours as per LM-80 report)
10**.** The luminaries shall be protected a gainst surges and transients and transie nts of	>/=10KV(External) & >/=5KV (Internal)
11. Warranty for free replacement:	Three years
12. Availability of test report for lumin aire	from Central Government Lab / NABL accr edited /ILAC accredited lab to prove confor mity of the speciation: As per IS 10322/Par t 5/Section 5 and IS 16107 /Part 2/section 1
13. Mounting bracket	Adjustable
14. Beam Angle & light source	120deg c & SMD LED chip as per LM 80/IS1 6106
15. operating temperature range	up to 50 deg c
16. CRI & Total Harmonic Distortion (in % age)	>=70 & < =10
17. Number of electronic control gear (P ower supply)	02 no’s
18. driver efficiency	> = 85
19. Luminaries system efficiency (Lume n/Watt)	>/=100Lm/Watt
20. Heat sink should be die-cast Alumin um along with sufficient heat sink fins to dissipate heat effectively.	Yes
21. Manufacturing Details	engraved/ Embossed in on the die cast bod y

22. Toughened transparent glass cover thickness	>/=4 mm
23. Test certificate	certification to be furnished to buyer on demand at time of supplies.

2. **Technical Specification/Golden parameter of 400-watt, flood light**

Parameter	Technical requirement
2. LED description	400-watt flood light
2. Ingress protection (IP Rating)	as per IS 10322 (Part 5/section 5):2012 latest, IP 66
3**.** Rated voltage:	230 V AC 50 Hz
4**.** Input operating voltage range, frequency and tripping	140-to-270-volt AC, 50 Hz with auto cut off below 120V and higher 300Volt
5**.** LED Luminaries as per the IS:16107(Part-2/sec-1)/2012 latest & Type of module as per the IS:16103(Part-2)/2012	Type B & type 3
6. Color Temperature (in K)	(+/-500K) 6500k
7**.** LED Luminaries for road and street lighting shall comply with	Compulsory Registration (CRS) of BIS for safety as per IS 10322 (Part 5/Section 3): 2012 as applicable on date.
8. Length of ISI marked three core wire (shall be provided **along with supply of material):**	50 cm minimum with each fitting.
9. Working life for LED	(Minimum 50,000 burning hours as per LM-80 report)
10**.** The luminaries shall be protected against surges and transients and transients of	>/=10KV(External) & >/=5KV (Internal)
11. Warranty for free replacement:	Three years
12. Availability of test report for luminaire	from Central Government Lab / NABL accredited /ILAC accredited lab to prove conformity of the speciation: As per IS 10322/Part 5/Section 5 and IS 16107 /Part 2/section 1
13. Mounting bracket	Adjustable

14. Beam Angle & light source	120deg c & SMD LED chip as per LM 80/IS16106
15. operating temperature range	up to 50 deg c
16. CRI & Total Harmonic Distortion (in % age)	>=70 & < =10
17. Number of electronic control gear (Power supply)	02 no’s
18. driver efficiency	> = 85
19. Luminaries system efficiency (Lumen/Watt)	>/=100Lm/Watt
20. Heat sink should be die-cast Aluminum along with sufficient heat sink fins to dissipate heat effectively.	Yes
21. Manufacturing Details	engraved/ Embossed in on the die cast body
22. Toughened transparent glass cover thickness	>/=4 mm
23. Test certificate	certification to be furnished to buyer on demand at time of supplies.

–

–

3. **Technical Specification/Golden parameter of 190-watt, flood light**

Parameter	Technical requirement
3. LED description	190-watt flood light
2. Ingress protection (IP Rating)	as per IS 10322 (Part 5/section 5):2012 as applicable on the date, IP 66
3**.** Rated voltage:	230 V AC 50 Hz
4**.** Input operating voltage range, frequency and tripping	140-to-270-volt AC, 50 Hz with auto cut off below 120V and higher 300Volt
5**.** LED Luminaries as per the IS:16107(Part-2/sec-1)/2012 latest & Type of module as per the IS:16103(Part-2)/2012	Type B & type 3
6. Color Temperature (in K)	(+/-500K) 6500k

7**.** LED Luminaries for road and street li ghting shall comply with	Compulsory Registration (CRS) of BIS for sa fety as per IS 10322 (Part 5/Section 3): 20 12 as applicable on date.
8. Length of ISI marked three core wire (shall be provided **along with supply o f material):**	50 cm minimum with each fitting.
9. Working life for LED	(Minimum 50,000 burning hours as per LM-80 report)
10**.** The luminaries shall be protected a gainst surges and transients and transie nts of	>/=10KV(External) & >/=5KV (Internal)
11. Warranty for free replacement:	Three years
12. Availability of test report for lumin aire	from Central Government Lab / NABL accr edited /ILAC accredited lab to prove confor mity of the speciation: As per IS 10322/Par t 5/Section 5 and IS 16107 /Part 2/section 1
13. Mounting bracket	Adjustable
14. Beam Angle & light source	120deg c & SMD LED chip as per LM 80/IS1 6106
15. operating temperature range	up to 50 deg c
16. CRI & Total Harmonic Distortion (in % age)	>=70 & < =10
17. Number of electronic control gear (P ower supply)	02 no’s
18. driver efficiency	> = 85
19. Luminaries system efficiency (Lume n/Watt)	>/=100Lm/Watt
20. Heat sink should be die-cast Alumin um along with sufficient heat sink fins to dissipate heat effectively.	Yes
21. Manufacturing Details	engraved/ Embossed in on the die cast bod y
22. Toughened transparent glass cover t hickness	>/=4 mm
23. Test certificate	certification to be furnished to buyer on de mand at time of supplies.

4.Technical Specification/Golden parameter of 100 watt Str eet light

Parameter	Technical requirement
4. LED description	100 watt Street light
2. Ingress protection (IP Rating)	IP 66
3**.** Rated voltage:	230 V AC 50 Hz
4**.** Input operating voltage range and fr equency & cut off	140-to-270-volt AC, 50 Hz with auto cut off below 120V and higher 300Volt
5**.** LED Luminaries Conforming to	IS 10322 (Part 5/Section 5) and IS 16107 (Part 2/Section 1)
6. Colour Temperature (in K)	(+/-500K) 6500
7**.** LED Luminaries for road and street li ghting shall comply with	Compulsory Registration (CRS) of BIS for sa fety as per IS 10322 (Part 5/Section 3): 20 12 as applicable on date.
8. Length of ISI marked three core wire (shall be provided **along with supply o f material):**	100 cm minimum with each fitting.
9. Other protection	Output short circuit protection, output over load protection, input over voltage protecti on, Input and output Reverse polarity and as per IS 10322/Part 5/section 3
10**.** The luminaries shall be protected a gainst surges and transients and transie nts of	>/=10KV(External) & >/=5KV (Internal)
11. Warranty for free replacement:	three year
12. Availability of test report for lumin aire	from Central Government Lab / NABL accr edited /ILAC accredited lab to prove confor mity of the speciation :As per IS 10322/Par t 5/Section3, LATEST
13. Mounting bracket	Adjustable
14. Beam Angle	120deg c
15. operating temperature range	up to 50 deg c
16. Humidity range	10% to 95% RH
17. Number of electronic control gear (P ower supply)	02 no’s
18. driver efficiency	> - 85

19. Luminaries system efficiency (Lume n/Watt)	>/=100Lm/Watt
20. Power factor	>0.9
21. Manufacturing Details	engraved/ Embossed in on the die cast bod y
22. Toughened transparent glass cover t hickness	>/=4 mm
23. Test certificate	certification to be furnished to buyer on de mand at time of supplies.

5.Technical Specification/Golden parameter of 20 watt, LED Tube light

Parameter	Technical requirement
1.LED description	20 watt LED BATTEN LIGHT
2. Rated voltage:	230 V AC 50 Hz
3**.** Input operating voltage range and fr equency	100-to-300-volt AC, 50 Hz
4**.** LED Luminaries Conforming to	IS 10322 (Part 5/Section 1) LATEST
5. Color Temperature (in K)	6500 (Cool white)
6. Length of batten & material	1150 mm/ 4 feet & poly carbonate electrica l grade
7**.** Warranty for free replacement:	One year
8. Type of test report	from Central Government Lab / NABL accr edited /ILAC accredited lab to prove confor mity of the speciation: to be indicated at ti me of bidding.
9. Manufacturing Details	engraved/ Embossed in on the body
11. Test certificate	certification to be furnished to buyer on de mand at time of supplies.

6.Technical Specification/Golden parameter of 150 watt, street light

Parameter	Technical requirement
5. LED description	150 watt street light

2. Ingress protection (IP Rating)	IP 66
3**.** Rated voltage:	230 V AC 50 Hz
4**.** Input operating voltage range and fr equency & cut off	140-to-270-volt AC, 50 Hz with auto cut off below 120V and higher 300Volt
5**.** LED Luminaries Conforming to	IS 10322 (Part 5/Section 3) ,LATEST
6. Color Temperature (in K)	(+/-500K) 6500
7**.** LED Luminaries for road and street li ghting shall comply with	Compulsory Registration (CRS) of BIS for sa fety as per IS 10322 (Part 5/Section 3): 20 12 as applicable on date and Particular Re quirements for LED Street lighting Luminair e conforming to IS 16107 (Part 2/Section 2)
8. Length of ISI marked three core wire (shall be provided **along with supply o f material):**	100 cm minimum with each fitting.
9. Other protection	Output short circuit protection, output over load protection, input over voltage protecti on, Input and output Reverse polarity and as per IS 10322/Part 5/section 3
10**.** The luminaries shall be protected a gainst surges and transients and transie nts of	>/=10KV(External) & >/=5KV (Internal)
11. Warranty for free replacement:	Three years
12. Availability of test report for lumin aire	from Central Government Lab / NABL accr edited /ILAC accredited lab to prove confor mity of the speciation: As per IS 10322/Par t 5/Section 3
13. Mounting bracket	Adjustable
14. Beam Angle	120deg c
15. operating temperature range	up to 50 deg c
16. Humidity range	10% to 95% RH
17. Number of electronic control gear (P ower supply)	02 no’s
18. driver efficiency	> = 85%
19. Luminaries system efficiency (Lume n/Watt)	>/=100Lm/Watt

20. Power factor	>0.9
21. Manufacturing Details	engraved/ Embossed in on the die cast bod y
22. Toughened transparent glass cover t hickness	>/=4 mm
23. Test certificate	certification to be furnished to buyer on de mand at time of supplies.

7.Technical Specification/Golden parameter of 190 watt Str eet light

Parameter	Technical requirement
6. LED description	190 watt Street light
2. Ingress protection (IP Rating)	IP 66
3**.** Rated voltage:	230 V AC 50 Hz
4**.** Input operating voltage range and fr equency & cut off	140-to-270-volt AC, 50 Hz with auto cut off below 120V and higher 300Volt
5**.** LED Luminaries Conforming to	IS 10322 (Part 5/Section 5) and IS 16107 (Part 2/Section 1)
6. Colour Temperature (in K)	(+/-500K) 6500
7**.** LED Luminaries for road and street li ghting shall comply with	Compulsory Registration (CRS) of BIS for sa fety as per IS 10322 (Part 5/Section 3): 20 12 as applicable on date.
8. Length of ISI marked three core wire (shall be provided **along with supply o f material):**	100 cm minimum with each fitting.
9. Other protection	Output short circuit protection, output over load protection, input over voltage protecti on, Input and output Reverse polarity and as per IS 10322/Part 5/section 3
10**.** The luminaries shall be protected a gainst surges and transients and transie nts of	>/=10KV(External) & >/=5KV (Internal)
11. Warranty for free replacement:	three year

12. Availability of test report for lumin aire	from Central Government Lab / NABL accr edited /ILAC accredited lab to prove confor mity of the speciation :As per IS 10322/Par t 5/Section 3 and IS 16107 /Part 2/section 1
13. Mounting bracket	Adjustable
14. Beam Angle	120deg c
15. operating temperature range	up to 50 deg c
16. Humidity range	10% to 95% RH
17. Number of electronic control gear (P ower supply)	02 no’s
18. driver efficiency	> - 85
19. Luminaries system efficiency (Lume n/Watt)	>/=100Lm/Watt
20. Power factor	>0.9
21. Manufacturing Details	engraved/ Embossed in on the die cast bod y
22. Toughened transparent glass cover t hickness	>/=4 mm
23. Test certificate	certification to be furnished to buyer on de mand at time of supplies.

–

–

8.Technical Specification/Golden parameter of 190 watt High Bay light

Parameter	Technical requirement
1.LED description	190-watt LED type High bay light
2. Ingress protection (IP Rating)	as per IS 10322 (Part 5/section 1):2012 as applicable on the date and IS: 16104:2012 latest, IP 66
3**.** Rated voltage:	230 V AC 50 Hz
4**.** Input operating voltage range and fr equency & cut off	140-to-270-volt AC, 50 Hz with auto cut off below 120V and higher 300Volt
5**.** LED Luminaries Conforming to	IS 15885 (Part 2/Section 13) LATEST

6. Color Temperature (in K)	(+/-500K) 6500
7**.** LED Luminaries for road and street li ghting shall comply with	Compulsory Registration (CRS) of BIS for sa fety as per IS 10322 (Part 5/Section 3): 20 12 as applicable on date.
8. Length of ISI marked three core wire (shall be provided **along with supply o f material):**	100 cm minimum with each fitting.
9. Working life for LED	(Minimum 50,000 burning hours as per LM-80 report)
10**.** The luminaries shall be protected a gainst surges and transients and transie nts of	>/=10KV(External) & >/=5KV (Internal)
11. Warranty for free replacement:	three year
12. Availability of test report for lumin aire	from Central Government Lab / NABL accr edited /ILAC accredited lab to prove confor mity of the speciation: As per IS 15885/Par t 2/Section 13 and IS 16107 /Part 2/section 1
13. Mounting bracket	Adjustable
14. Beam Angle	120deg c
15. operating temperature range	up to 50 deg c
16. Humidity range	10% to 95% RH
17. Number of electronic control gear (P ower supply)	02 no’s
18. driver efficiency	> = 85%
19. Luminaries system efficiency (Lume n/Watt)	>/=100Lm/Watt
20. Power factor	>0.9
21. Manufacturing Details	engraved/ Embossed in on the die cast bod y
22. Test certificate	certification to be furnished to buyer on de mand at time of supplies.

ELIGIBILITY/PROVENESS CRITERIA

ELIGIBLE FOR PARTICIPATION BY ANY PROSPECTIVE BIDDER

S. No.	Status of bidder	Documents	Compliance
1.	Proven Manufacturer	a) **Manufacturing Proof**- Valid registration certificate of DGS&D / NSIC / DIC / Registrar of companies/ISO certificates, any other document issued by Govt. agency as a proof of manufacturer of the tendered items or equipment. b) **Proven source** -To submit copy of supply order along with copy of receipt of Challan/ Tax invoices etc. in support that tendered / offered item(s) (for spares) or tendered item(s) of same or higher specifications (for consumables) have been supplied during the last 05 (five)years from the date of opening of tender against orders of CIL and its subsidiaries, PSU., Govt departments and private organisations and their performance has been found satisfactory. c) **Performance certificate from end user**- Satisfactory Performance certificate issued by the end user to be submitted along with the offer. **OR** **Self Certificate to be submitted by the bidder**- The items covered in the purchase orders (s) / rate contract(s) copies enclosed with our offer have been fully executed and have performed satisfactorily as per the provisions of respective purchase order(s) / Rate contract(s) and all the complaints / claim lodged by the purchaser have been attended to and no complaints / claims(s) are pending	

2.	Authorised dealer of the Manufacturer	a) Valid Authorization certificate of manufacturer. b) **Proven source** -To submit copy of supply order along with copy of receipt of Challan/ Tax invoices etc. in support that tendered / offered item(s) (for spares) or tendered item(s) of same or higher specifications (for consumables) have been supplied by the manufacturer during the last 05 (five)years from the date of opening of tender against orders of CIL and its subsidiaries, PSU. , Govt departments and private organisations and their performance has been found satisfactory. c) **Performance certificate from end user**- Satisfactory Performance certificate issued by the end user to be submitted along with the offer. **OR** **Self Certificate to be submitted by the bidder**- The items covered in the purchase orders (s) / rate contract(s) copies enclosed with our offer have been fully executed and have performed satisfactorily as per the provisions of respective purchase order(s) / Rate contract(s) and all the complaints / claim lodged by the purchaser have been attended to and no complaints / claims(s) are pending	
3.	If the bidder is claiming exemption for Experience criteria / Proven source criteria	**MSE of Tendered product-** UDYAM certificate issued by MOMSE for Tendered / offered product. The bidder may submit NSIC etc. Or Duly filled Annexure A for proving technical capability. **OR** **Start Up-** Certificate of recognition as Start Up as per extant guidelines for tendered item. The bidder may submit NSIC etc. Or Duly filled Annexure A for proving technical capability.	

Declaration for offered product	**a) Make** **b) Model if any** **c) Test certificate if asked for in bid** **d) Fitment certificate** (for spares only)- To be uploaded a certificate to the affect that " We do hereby certify that our product is/ are exact replacement of / fully interchangeabe to the original parts and will fit and function on the equipment for which these are intended for without any modification and conforms to performance guarantee as OEM standards ." **e) Guarantee/ warranty certificate**- Bidder should provide standard guarantee / warranty of 12 months from the date of fitment or 18 months from the date of receipt of material at store which ever is earlier.	

–

–

–

–

A) Bid specific Authorization from the O.E.M is to be submitted at t he time of submission of offer.

B)Make is mandatorily required to be submitted in Bid itself. The bid without make and mod el wi l n ot be considered technically acceptable. The bidder must refrain from providing Make as NA, Unbr anded, Multiple makes, Blank, etc., Bids with such details will not be tech nically acceptable .

. EMD can be paid by any of the mode either BG or DD. Earnest Money Deposit (EMD)

: EMD can be deposited in the form of DD in favour of SE CL Gevra Area, District- Korba (C.G) pay able at SECL Gevra Area, District-Korba(C.G) Pincode-495452. .

EMD should reach on the following address:

Staff Officer (MM) Office of the Area General Manager South Eastern Coalfield Limited Gevra Area District-Korba (C.G) Pincode-495452.

ANNEXURE-A

PROFORMA FOR EQUIPMENT AND QUALITY CONTROL

(To be submitted by the Startups / MSE firms who claim the relaxation of the prior turnov er and prior experience criteria, as per clause no: 19A of the NIT)

Reference : CIL/Subsidiary Co._____ Tender No._____

Date_____for supply of_____

1. Name and Address of the Firm
2. a) Telephone No. office/factory/works
   b) Fax No. / E-mail ID
3. Location of manufacturing works/factories owned by the firm (documentary evidence of ownership must be produced).
4. Brief description of the factory (i.e. area covered accommodation, Department into which it is divic ed, laboratory etc.)

5. Details of plant and machinery erected and functioning in each department (monographs and desc
   ription pamphlets) be supplied if available.
6. Whether the process of manufacture in the factory is carried out with the aid of power or without it
   .
7.Process Flow Chart for the whole manufacturing process of the tendered item.
8. Details and stocks of raw materials held.
9. Capacity of items quoted for with the existing plants and machinery
   (a) Normal
   (b) Maximum
10. Details of arrangements for quality control products such as laboratories etc.
11. (a) Details of technical supervisory staff in-charge of production and quality control.
    (b) Skilled labour employed.
    (c) Unskilled labour employed
    (d) Maximum number of workers (skilled and unskilled) employed on any day during 18 months p
   receding the date of application.
12.Whether stores were tested to any standard specification, if so, copies of original test certificate s
   hould be submitted in duplicate.

(Signature of Tenderer)

NOTE: Details against sl nos. 5 to 12 inclusive need be restricted to the extent they pertain to the ite
ms under reference

NOTE-

**Prior to commencement of regular supply, the s
uccessful bidder shall submit 3 (Three) samples
of the light fitting to SECL, Gevra Area, for inspe
ction and approval. Regular supply shall comme
nce only after the sample submitted by the bidd
er has been inspected and accepted by the inspe
cting Authority.**

**Inspection of the sample shall be completed
within Five (5) days from the date of receipt of t
he sample at the designated site.**

**If the sample fails to meet the specifications and
requirements stipulated in the bid, the bidder sh
all arrange for submission of a fresh sample com
plying with the bid requirements. The bidder sha
ll be permitted a maximum of two (2)**

opportunities for sample submission, including the initial submission. Failure to obtain sample approval within these two opportunities shall be dealt with as per the applicable terms and conditions of the bid.

The stipulated delivery period shall be inclusive of the time required for sample submission, inspection, acceptance, and supply of the complete consignment. No additional time or extension of the delivery period shall be granted for sample submission, inspection, or acceptance.

All costs associated with sample preparation, transportation, submission, and resubmission, if any, shall be borne entirely by the bidder.

Items are very-very critical for 24*7 mining operation Hence,100% supplied material shall be checked as per approved sample and in case of failure action will be initiated as per GeM GTC.

.

11. **Buyer Added Bid Specific ATC**

    Buyer uploaded ATC document Click here to view the file.

12. **Sample Clause**

    After award of contract – Successful Bidder shall have to get advance sample approved from buyer before bulk manufacturing / starting bulk supplies. Successful Bidder shall submit

    3
    samples for Buyer's approval, within 10 days of award of contract. Buyer shall, as per contract specifications framework, either approve the advance sample or will provide complete list of modification required in the sample within 5 days of receipt of advance sample. Seller shall be required to ensure supply as per approved sample with modifications as communicated by Buyer. If there is delay from buyer side in approval of advance sample – the delivery period shall be refixed without LD for the period of delay in sample approval. In case, the sample is found to have major deviations / not conforming to the Contract specifications, the buyer at its discretion may call for fresh samples for approval before allowing bulk supplies or may terminate the contract after notifying the deviations to the seller.
    Unless otherwise provided in the contract, all samples required for test shall be supplied by the contractor free of cost. Where under the contract, the contractor is required to submit an advance sample, any expenses incurred by the contractor on or in connection with the production of stores in bulk, before the sample has been approved unconditionally shall be borne by the Seller and he shall not claim any compensation in the

event of such sample being found unacceptable by the Buyer / Consignee.

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer ,is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid.All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM.If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents (other than EMD and signed Integrity Pact - which can be submitted within 5 days of bid opening) in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or

notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसक अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---